

EN12101-2:2003

UKCA Certified NSHEV Solutions

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 12101-2

June 2003

English version

Smoke and heat control systems - Part 2: Specification for natural smoke and heat exhaust ventilators

Rauch- und Wärmehaushaltung - Teil 2: Festlegungen für natürliche Rauch- und Wärmehaushaltung

Systèmes pour le contrôle des fumées et de la chaleur -
Partie 2: Spécifications pour les dispositifs d'évacuation de
fumées et de chaleur

This European Standard was approved by CEN on 3 April 2003.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving the European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey, United Kingdom and Ukraine.

Official Journal of the European Union

4.4.2011

REGULATION (EU) No 305/2011 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL
of 9 March 2011
laying down harmonised conditions for the marketing of construction products and repealing Council Directive 89/106/EEC
(Text with EEA relevance)

THE EUROPEAN PARLIAMENT AND THE COUNCIL OF THE

Member States have introduced provisions, but requirements, relating not only to safety of buildings, but also to health, and other construction works but also to health, safety, energy efficiency, protection of the environment, and other important aspects.



deceuninck

The information in this document is correct at the time of issue, however is subject to change.

11/2025 - Rev A

UK
CA

Creating a Healthier &
Safer Environment

1

Deceuninck Traditional 2500 & Heritage 2800 SE Controls NSHEV

It is a mandatory requirement under the Construction Products Regulations (Regulation (EU) No 305/2011) for Natural Smoke and Heat Exhaust Ventilators (NSHEVs) to be UKCA certified as conforming to the Harmonised Standard EN12101-2:2003.

Deceuninck and SE Controls have collaborated on an extensive test and certification program with IFCC, a UK Notified Body (Notified Body Nr. 1720) to meet this requirement and ensure a seamless façade installation and performance can be provided.

The following Deceuninck frame systems can be certified under SE Controls' Tested Solutions program.

Frame System	Applications	Refer to
Deceuninck Traditional 2500	Side Hung, Bottom Hung Open Out	Section 4.1
Deceuninck Heritage 2800	Side Hung, Bottom Hung Open Out	Section 4.1

2 **Manufacturing**

Prior to manufacturing an NSHEV it is important to seek guidance from SE Controls to ensure the NSHEV is manufactured under an annually audited EN12101-2 System 1 Factory Production Control process.

It is mandatory this is in place before manufacturing. Please register your interest to Façade.technical@secontrols.com

If an NSHEV is not manufactured under an EN12101-2 System 1 Factory Production Control process the product will not be certifiable by SE Controls.



Contact the SE Controls Façade Support Team

SE Controls
Lancaster House, Fradley, Lichfield
WS13 8RZ
Tel +44 1543 443060

Creating a **Healthier & Safer** Environment

3 Certification

3.1 Essential Characteristics declared on the SE Controls NSHEV Declaration of Performance (DoP) as defined by EN12101-2:2003 Annex ZA.1.

CCP 1720-CPR-0225		
Essential Characteristics	Clauses in This European Standard	Mandated Level(s) or Class(es)
Nominal Activation Conditions/sensitivity	4.1 4.2	24V dc.
Response relay (Time relay)	7.1.2	<60s
Operational Reliability	7.1 7.4	Re 1000 NPD Single Chain WL1250 Twin Chain Only
Effectiveness of smoke/hot gas extraction	6.	Pass
Aerodynamic free area	6.	Pass
Performance parameters under fire conditions	7.5	30
Resistance to fire – Mechanical stability	7.5	B300
Ability to open under environmental conditions	7.2 7.3	T(00) SL(0)
Fire reaction	7.5.2.1	NPD

“PASS”; Each NSHEV will have a specific aerodynamic free area based upon its dimensions, opening angle and applicable coefficient of discharge (Cv) of between 0.31 and 0.62.

3.2 Factory Production Control

The vent is manufactured, the actuator installed and the NSHEV completed under SE Controls' System 1 Factory Production Control (FPC) process, audited by the Approved Body, IFCC in accordance with the requirements of the Construction Products Regulation (EU) No 305/2011 and EN12101-2:2003 product standard.

The Certificate of Constancy of Performance (CoCoP) issued by IFCC and Declaration of Performance (DoP) issued by SE Controls confirms the audited system 1 FPC process is in place.

The NSHEV is certified and placed upon the market by SE Controls in the capacity of the manufacturer.



Contact the SE Controls Facade Support Team

SE Controls
Lancaster House, Fradley, Lichfield
WS13 8RZ
Tel +44 1543 443060

Creating a **Healthier & Safer** Environment

4 Deceuninck SE Controls NSHEV Certifiable Parameters

4.1 Traditional 2500 & Heritage 2800

Orientation	Maximum Outer Frame Width	Maximum Outer Frame Height	Minimum Outer Frame Width	Minimum Outer Frame Height	Maximum Weight	Hinges	Actuator
Side Hung	1082mm	1500mm	500mm	785mm	50Kg	Mila Ideal Butt Hinge 0223020	SECO Ni 24 40 Actuator Single
Side Hung	1082mm	2282mm	500mm	1445mm	75Kg	Mila Ideal Butt Hinge 0223020	SECO Ni 24 40 Actuator Twin
Bottom Hung	1582mm	1200mm	785mm	500mm	60Kg	Mila Ideal Butt Hinge 0223020	SECO Ni 24 40 Actuator Single & Twin

Any make up of double-glazed unit or triple-glazed unit can be assessed providing the weight of the vent remains within maximum weight limitation stated above.

4.2 Sash/Frame Combinations

2500 Traditional

Frame Reference	Sash Reference	Prep Detail Reference (Single Chain)	Prep Detail Reference (Twin Chain)
2533	2538	SEF_2412	SEF_2413

2800 Heritage

Frame Reference	Sash Reference	Prep Detail Reference (Single Chain)	Prep Detail Reference (Twin Chain)
2833	2829	SEF_2414	SEF_2415

Steel reinforcing must be installed in both sash and frame sections and mechanically fixed as per the Deceuninck AOV technical manual.



Contact the SE Controls Facade Support Team

SE Controls
Lancaster House, Fradley, Lichfield
WS13 8RZ
Tel +44 1543 443060

Creating a **Healthier & Safer** Environment

5 System Design and Installation Considerations

5.1 Free Area

The free area essential characteristic of an NSHEV is declared on the Declaration of Performance as “Aerodynamic Free Area”. Often building codes do not specify aerodynamic free areas, but instead require a Geometric Free Area (e.g., 1.5m²) and the two methods should not be confused.

A Geometric Free Area will be larger than the Aerodynamic Free Area for the same NSHEV, but they are not directly comparable.

Refer to the applicable design standard BS 9991:2024 (Section 20.1. Table 3 - Summary of Smoke Control Provisions)

Top Of stair Vent for a building below 11 meters tall: 0.7m² (Aerodynamic Free Area)

Top Of stair Vent for a building above 11 meters tall: 0.7m² (Aerodynamic Free Area)

Lobby / Corridor vent for a building above 11 meters tall: 0.9m² (Aerodynamic Free Area)

5.2 Controls

NSHEVs must be operated by a compatible EN12101-10 compliant control system; SE Controls recommends its OS series of control systems.

5.3 Safety: Entrapment Protection

Consideration should be given to the installation of suitable measures to mitigate the risks of entrapment.

NSHEVs should be closed/ reset via a local Manual Control Point (MCP) with a ‘biased off principle’*, or alternative safety measures/ operational procedures should be considered.

*Smoke Control Association: Guidance on Smoke Control to Common Escape Routes in Apartment Buildings (Flats and Maisonettes) Revision 3.1: July 2020

For advice on further safety considerations contact SE Controls.

5.4 Safety: Fall Restraint

Consideration should be given to the installation of suitable measures to mitigate the risks of falling through an NSHEV.

For advice on additional window restraint options contact SE Controls.

5.5 Installation & Maintenance

A smoke ventilation system should be designed, installed and maintained by a suitably competent and trained smoke ventilation specialist.

6 Support

Contact the SE Controls Technical Façade Team – Façade.technical@secontrols.com

SE Controls, Lancaster House, Wellington Crescent, Fradley, Lichfield, Staffs WS13 8RZ

Tel. +44 1543 443060 Website: www.secontrols.com



Contact the SE Controls Façade Support Team

SE Controls
Lancaster House, Fradley, Lichfield
WS13 8RZ
Tel +44 1543 443060

Creating a **Healthier & Safer** Environment