



DECLARATION OF PERFORMANCE

Document Ref SEP-1970-06.23



1	Unique Identification Code of Product Type: SE Controls OSLoop Coordinator Panel; Item FCS 0030 0010									
2	Manufacturing Date Code and Serial Number: As appears on product (MM.YY XXXXXXXX)									
3	Intended Use The control of actuators and other devices forming part of a smoke control ventilation system.									
4	Name of Manufacturer: SE Controls, Wellington Crescent, Fradley Park, Lichfield, Staffs, UK. WS13 8RZ Tel: +44 (0)1543 443060. Web: www.secontrols.com									
5	Authorised Representatives: Not applicable									
6	System of Assessment and verification of constancy of performance: System 1									
7	Designated Standard covered by Construction Products Regulation: EN 12101-10:2005 Smoke and Heat Control Systems -Power Supplies.									
8	EU Notified Body: KIWA FSS Products, Wilmersdorf 50, 7327 Apeldoorn, NL Approved body number; 0063 Performed the initial inspection of the manufacturing plant and of factory production control (FPC), and the continuous surveillance, assessment and evaluation of FPC, and issued the certificate of constancy of performance. Certificate ref 0063-CPR-222190009/00									
9	<table border="1"> <tr> <td colspan="2">Essential Characteristics:</td> <td rowspan="4">EN 12101-10:2005</td> </tr> <tr> <td>Operational Reliability</td> <td>Pass.</td> </tr> <tr> <td>Performance Parameters under Fire Conditions</td> <td>Class A Environmental Class 1</td> </tr> <tr> <td>Response Time</td> <td>Interruption Time <0.05 sec</td> </tr> </table>	Essential Characteristics:		EN 12101-10:2005	Operational Reliability	Pass.	Performance Parameters under Fire Conditions	Class A Environmental Class 1	Response Time	Interruption Time <0.05 sec
Essential Characteristics:		EN 12101-10:2005								
Operational Reliability	Pass.									
Performance Parameters under Fire Conditions	Class A Environmental Class 1									
Response Time	Interruption Time <0.05 sec									
10	<p>The performance of the product identified in sections 1 and 2 above is in conformity with the declared performance in section 9 above.</p> <p>The declaration of performance is issued under the sole responsibility of the manufacturer identified in section 4 above.</p> <table border="1"> <tr> <td>Rev 1 Date:</td> <td>01 June 2023</td> <td>Signed:</td> <td></td> </tr> <tr> <td>Place of Issue:</td> <td>Lichfield, UK</td> <td colspan="2">Mark Soleil, Operations Director</td> </tr> </table>	Rev 1 Date:	01 June 2023	Signed:		Place of Issue:	Lichfield, UK	Mark Soleil, Operations Director		
Rev 1 Date:	01 June 2023	Signed:								
Place of Issue:	Lichfield, UK	Mark Soleil, Operations Director								

N:\Electronics\Design\13113010 Part 10 Compliance Docs\OSLoop\Appendix 26 CPR Declaration of Performance\SEP1970 0623 OSLoop CE Declaration of Performance 12101_10_2023 Rev 2.docx

Lancaster House
Wellington Crescent
Fradley Park, Lichfield
Staffordshire WS13 8RZ

+44 (0)1543 443060
sales@secontrols.com
www.secontrols.com

